ACCESSORIES

Boilers with high turndown rates require gas regulators that provide stable pressure regulation, not only at the maximum firing rate, but also at the minimum firing rate. Lochinvar regulators are sized to accommodate inlet regulator pressures up to 2 psi or 10 psi and are 100% bubble tight lock up. All regulators are direct acting and allow for 500:1 turndown to function more effectively with today's highturndown boilers.

How to size: Find the unit gas connection size below that matches the boiler gas connection size.


Note: For the Crest FB/OF 6001 use the 3" unit gas connection size.

GAS REGULATORS



STANDARD FEATURES

- ANSI Z21.80A-2019/CSA 6.22A-2019 Class I for outlet pressures up to 14" Certified
- Integral vent limiter
- CSA approved External Vent Limiter no vent line required*
- 500:1 Turndown
- Positive 100% bubble tight lock up regulator
- Suitable for NG and LP
- · Suitable to indoor or outdoor installation
- Up to 2 PSIG and 10 PSIG inlet pressures available
- 10 PSIG inlet models are Over Pressure Device (OPD), Worker & Monitor style



SAP Number	Inlet Pressure Rating	Outlet Pressure Rating	Unit Gas Conn. Size	Α	В	С	D	E	Ship Wt. (lbs)
100269922	3" W.C. to 2 PSIG	2" W.C. to 14" W.C.	1-1/4"	7-3/4"	-	1-1/4" NPT	10"	-	8
100269923	3" W.C. to 2 PSIG	2" W.C. to 14" W.C.	1-1/2"	7-3/4"	-	1-1/2" NPT	10"	-	8
100269924	3" W.C. to 2 PSIG	2" W.C. to 14" W.C.	2″	9-1/4"	-	2" NPT	12-1/2"	-	13
100269925	3" W.C. to 2 PSIG	2" W.C. to 14" W.C.	2-1/2"	-	17"	2-1/2" Flanged	-	17-1/4"	28
100320057	3" W.C. to 2 PSIG	2" W.C. to 14" W.C.	3″		17"	3" Flanged		16-3/4"	28
100320058	7" W.C. to 10 PSIG	2" W.C. to 14" W.C.	1-1/4"	16-3/4"		1-1/4" NPT	9-1/2"		16
100320059	7" W.C. to 10 PSIG	2" W.C. to 14" W.C.	1-1/2"	16-3/4"		1-1/2" NPT	9-1/2"		16
100320060	7" W.C. to 10 PSIG	2" W.C. to 14" W.C.	2″	20"		2" NPT	12"		25
100320061	7" W.C. to 10 PSIG	2" W.C. to 14" W.C.	2-1/2"		34"	2-1/2" Flanged		16-3/4"	56
100320062	7" W.C. to 10 PSIG	2" W.C. to 14" W.C.	3″		34"	3" Flanged		16-3/4"	56

^{*}Brass Vent Limiters must be removed for outdoor installation.



BGR-04 (replace BRG-03 8/19) ASB - 500 3/2021 -Printed in U.S.A.